



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	3774-0923:0501
CATEGORY:	3774 - ELECTRIC LOCKS
LISTEE:	Securitron Magnalock 10027 S. 51st St., Ste. 102, Phoenix, AZ, 85044 Contact: Peabody, Josh (623) 582-4626 (866) 582-4611 Email: josh.peabody@assaabloy.com
DESIGN:	Model DEM680E Special Locking Arrangement Delayed Egress Electromagnetic Door Lock. Model DEM680E may include suffix -CA15S for 15 seconds fixed exit delay. Intended to be mounted to the underside of the door frame header and operate by direct force on outward swinging non-fire rated doors only, with an egress delay time not to exceed 15 seconds. For indoor use only. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	12/24 VDC
INSTALLATION:	In accordance with listee's printed installation instructions, NFPA 101, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, rating, and UL label.
APPROVAL:	Listed as delayed egress electromagnetic door lock for use with outward swinging non-fire rated doors when installed in accordance with the California Building Code. Authority having jurisdiction shall be consulted prior to installation. Refer to listee's Installation Instruction Manual for details.
NOTES:	

7-29-21 VWW



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 03/14/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division